



CERTIFICATE

No. E-2- 22499

for safety of electrical instalations products

Product: **JUNCTION BOX FOR LIGHTING POLES**

Manufacturer/Brand name: **EXTEH d.o.o.**

Type: **RRS 08/* (18.37.**)**

Applicant: **EXTEH d.o.o.**
Zagrebačka cesta 156 F
10000 ZAGREB

Parameters:	
1) Rated voltage:	500V AC
2) Rated current:	25A
3) Protection class:	II
4) Degree of protection:	IP 54
5) Components:	Terminals for cable connection (I/O) 4x6-35mm ² Terminals for L/F (load) 4x1,5-4mm ²
6) Note:	* =1,2,3,4,5,6,7,8 (different type of fuses, number of fuses I/O cable terminal – alu aloy (for Al and Cu condutors) for pole diameter 100mm (inside)
7) State of origin:	CROATIA

Test report number and date: E-2-17481 / 25.03.2014.

CONCLUSION

It is certified hereby that the product characteristics are in conformity to the requirements of the following regulations and standards:

- Rules for el. low voltage apparatus (Official Gazette N.N. 41/2010.)
- HRN EN 60439-1:2005+A1:2005
- HRN EN 60439-5:2008
- HRN EN 60670-1:2007
- HRN EN 60670-24:2011
- IEC 61545:1996
- HRN EN 60529:2000+A1:2008
- DIN VDE 0660-505:1998

Valid until: 26.03.2016

Date: 26.03.2014.



Signature of authorized person:

Damir Jakopović, dipl.ing.

DECLARATION OF CONFORMITY

<i>Applicant:</i>	EXTEH d.o.o. Zagrebačka cesta 156 F 10000 ZAGREB
<i>Product:</i>	JUNCTION BOX FOR LIGHTING POLES
<i>Type:</i>	RRS 08/* (18.37.**)
<i>Manufacturer/ Brand name:</i>	EXTEH d.o.o. - CROATIA

***This product is in conformity to the requirements
of the following regulations and standards:***

- Rules for el. low voltage apparatus (Official Gazette N.N. 41/2010.)
- HRN EN 60439-1:2005+A1:2005
- HRN EN 60439-5:2008
- HRN EN 60670-1:2007
- HRN EN 60670-24:2011
- IEC 61545:1996
- HRN EN 60529:2000+A1:2008
- DIN VDE 0660-505:1998

CERTIFICATE No. E-2-22499 , dated 26.03.2014.

(Ev.Nr. 17481)

issued by: Zavod za ispitivanje kvalitete d.o.o. - Zagreb

Date: 26.03.2014.

Seal

For EXTEH d.o.o.:
Signature of authorized person:

»EXTEH« d.o.o.
ZAGREB 2

