

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage fuse-holders for cylindrical fuse-links

Name and address of the applicant

DF ELECTRIC, S.A.
Silici, 67-69,
08940 CORNELLA DE LLOBREGAT (Barcelona), Spain

Name and address of the manufacturer

DF ELECTRIC, S.A.
Silici, 67-69,
08940 CORNELLA DE LLOBREGAT (Barcelona), Spain

Name and address of the factory

DF ELECTRIC, S.A.
Silici, 67-69,
08940 CORNELLA DE LLOBREGAT (Barcelona), Spain

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

AC 690 V, 50 Hz or DC 24 V; 32 A
1-pole, N-pole, 1+N-pole, 2-pole, 3-pole, 3+N-pole, 4-pole
for 10x38 fuse-links

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

PMX-10

Additional information (if necessary may also be reported on page 2)

--

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-18276/DF-S.A/60269-1/PMX-10,
SGP-18276/DF-S.A/60269-2/PMX-10

This CB Test Certificate is issued by the National Certification Body

Österreichischer Verband für Elektrotechnik
Testing and Certification
Kahlenberger Str. 2A, 1190 Wien, AustriaDigitally signed by W. Martin
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin

Date: 2020-02-10