



Ref. Certif. No.

AT 3994

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-Voltage Fuse-Switch-Disconnecter

Name and address of the applicant

Jean Müller GmbH Elektrotechnische Fabrik
H.J.-Müller-Straße 7,
65343 Eltville am Rhein, Germany

Name and address of the manufacturer

Jean Müller GmbH Elektrotechnische Fabrik
H.J.-Müller-Straße 7,
65343 Eltville am Rhein, Germany

Name and address of the factory

Jean Müller GmbH Elektrotechnische Fabrik
H.J.-Müller-Straße 7,
65343 Eltville am Rhein, Germany

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

Ue = AC 400-690V; Ie = 250A; 4-pole;
AC-21B: 690V/250A; AC-22B: 500V/250A; AC-23B: 400V/250A. For
use with fuse-links NH1 up to 250A with max. power-loss of 23W.

Trademark (if any)

JEAN MÜLLER 

Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

KETO-1-4/...,
see also page 4 of test report for details

Additional information (if necessary may also be reported on page 2)

--

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 IEC 60947-3:2008
IEC 60947-1:2007/AMD1:2010 IEC 60947-3:2008/AMD1:2012
IEC 60947-1:2007/AMD2:2014 IEC 60947-3:2008/AMD2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-01879/KETO 1-4/CB

This CB Test Certificate is issued by the National Certification Body

Österreichischer Verband für Elektrotechnik
Testing & Certification
Kahlenberger Str. 2A, 1190 Wien, Austria

Date: 2018-07-04

Digitally signed by W. Martin
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin