

CERTIFIKAT
CERTIFICATE

Broj / No: **LVD 30210014**

Proizvod: Kućni priključni tavanski ormar
Product: Household distribution attic board

Tip/model: KPTO-1f, KPTO-3f (vidi prilog/see enclosure)
Type/model

Podnositelj zahtjeva: EXTEH d.o.o., Sertićeve ledine 3, 10090 Zagreb
Applicant:

Proizvođač: EXTEH d.o.o., Sertićeve ledine 3, 10090 Zagreb
Manufacturer:

Primijenjene norme: HRN EN 61439-1:2012 (IEC 61439-1:2011)
Related standards: HRN EN 61439-2:2012 (IEC 61439-2:2011)
HRN EN 62208:2012 (IEC 62208:2011)

Broj i datum izvještaja o ispitivanju: 34/2586 od/by 19.03.2021.
Test report No and date of issue: LA-20.110/20.071/E od/by 28.12.2020.

Ispitni izvještaj izdan od: Končar - Institut za elektrotehniku/*Electrical Engineering Institute*, Zagreb:
Test report issued by the: - Laboratorijski centar/*Laboratory center*
BBJ-SEP, Testing Laboratory, Varšava/*Warsaw*

ZAKLJUČAK:

Ovime se potvrđuje da je tip proizvoda sukladan zahtjevima gore navedenih normi.

CONCLUSION:

The sample of the product is in accordance with requirements of the standards listed above.

Napomena:

Ovaj dokument je potvrda o sukladnosti ispitnog uzoraka. Za sukladnost svakog proizvoda identične tipske oznake kao i ispitnog uzorka odgovoran je podnositelj zahtjeva.

Remark:

This document is a certificate of conformity of the tested sample. The applicant is responsible for conformity of product with the same type/model name.

Rok valjanosti:
Period of validity:

12.04.2024.

Ocjenitelj
Assessor

Miro Lončar, dipl.ing.

M.P.
Seal

**KONČAR - Institut za
elektrotehniku d. d.
Z A G R E B 12**

Mjesto i datum:
Place and date:

Croatia, Zagreb, 13.04.2021.

Upravitelj SCERT-a
Head of SCERT Department

Sanda Kozlik, dipl.ing., MBA