

CERTIFIKAT

CERTIFICATE

Broj / No: **LVD 30220003**

Proizvod: RAZVODNI ORMARI
Product *Distribution boards*

Tip/model: S-KRO/SD i MRO (vidi prilog/see enclosure)
Type/model

Podnositelj zahtjeva: EXTEH d.o.o., Sertićeve ledine 3, 10090 Zagreb
Applicant

Proizvođač: EXTEH d.o.o., Sertićeve ledine 3, 10090 Zagreb
Manufacturer

Primijenjene norme: HRN EN 61439-1:2021 (IEC 61439-1:2020)
Related standards HRN EN 61439-2:2021 (IEC 61439-2:2020)
HRN EN 61439-5:2015 (IEC 61439-5:2014)
HRN EN 62208:2012; (IEC 62208:2011)

Broj i datum ispitnog izvještaja: 34/2469 od/by 09.11.2018.
Test report No. and date LA-14.069/14.032/E od/by 29.04.2014.
LA-14.128/14.120/2/E od/by 08.11.2016.

Ispitni izvještaj izdao: Končar - Institut za elektrotehniku, Laboratorij za velike snage, Zagreb
Test report issued by BBJ-SEP, Testing and Certification Institute, Varšava
Koncar - Electrical Engineering Institute, High Power Laboratory, Zagreb
BBJ-SEP, Testing Laboratory, Warsaw

ZAKLJUČAK:

Ovime se potvrđuje da je tip proizvoda sukladan zahtjevima navedenih normi

CONCLUSION:

The sample of the product is in accordance with requirements of the standards listed above.

NAPOMENA:

Ovaj dokument je potvrda o sukladnosti ispitnog uzoraka. Za sukladnost svakog proizvoda identične tipske oznake kao i ispitnog uzorka odgovoran je podnositelj zahtjeva.

REMARK:

This document is a certificate of conformity of the tested sample. The applicant is responsible for conformity of product with the same type/model name.

Mjesto i datum izdavanja: Croatia, Zagreb, 21.03.2022.
Place and date of issue:

Ovaj certifikat vrijedi do: 20.03.2025.
This Certificate is valid until:

Ocjenitelj
Assessor
Digitalno potpisao:
MIRO LONČAR
Datum: 2022.03.21
12:13:55 +01'00'
Miro Lončar, dipl.ing.



Upravitelj SCERT-a
Head of SCERT Department
Digitally signed
by SANDA KOZLIK
Date: 2022.03.21
15:40:41 +01'00'
Sanda Kozlik, dipl.ing., MBA

Ovaj certifikat ne smije se umnožavati, osim u cijelosti i s pripadajućim prilogima ako postoje, bez odobrenja KONČAR - Instituta za elektrotehniku d.o.o.
This certificate shall not be reproduced except in full and followed by related enclosures, if any, without the written approval of KONČAR - Electrical Engineering Institute Ltd.

Končar - Electrical Engineering Institute Ltd., Fallerovo šetalište 22, 10000 Zagreb, Croatia, www.koncar-institut.hr
Phone: 385 1 3655277, e-mail: info@koncar-institut.hr • scert@koncar-institut.hr